



13 November 2020
Our Ref: 20GCA0101 L01_0
Your Ref:

Spring Creek Land Corporation Pty Ltd

C/- ADG Engineers
Attention: Michael Lepelaar

Dear Michael,

RE: Spring Creek Estate 22A Telemon Street, Beaudesert - Acoustic Certification of Stage 1 Noise Barrier

TTM were engaged by Spring Creek Land Corporation to conduct an acoustic certification inspection of the constructed acoustic barrier at Stage 1 of the Spring Creek Estate development at 22A Telemon Street, Beaudesert.

The inspection was made to determine if the acoustic barrier is built in accordance with the recommendations detailed in the TTM acoustic report (ttm ref: 14GCA0177 R01_2 Stage 1 & 2) dated 19 May 2016 and the Department of Transport and Main Roads Conditional Construction Approval CM13404.

The acoustic barrier was inspected on Friday 13/11/2020 with the following observations:

- a. Barrier height complies in all locations, with the 1.8m high requirement of the acoustic report.
- b. Barrier length and returns are built in accordance with, and for the extents shown, in the acoustic report.
- c. The barrier is constructed of modular acoustic wall panels that comply with the surface mass requirements stated in the acoustic report.
- d. The barrier is free of holes and gaps.

Based on these details, TTM certify that installed acoustic barrier at Stage 1 complies with the requirements and recommendations of the approved TTM acoustic report (ttm ref: 14GCA0177 R01_2 Stage 1 & 2) dated 19 May 2016.

We trust this information meets with your current requirements. Should you have any queries please do not hesitate to contact TTM.

Yours faithfully,

Jason Fox MAAS
Lead Consultant
[TTM Consulting Pty Ltd](#)